




National Supervision and Inspection Center for Explosion Protection
and Safety of Instrumentation (NEPSI)

Ex marking: [Ex ia Ga] IIC

[Ex ia Da] C

Um: 250V

Certified parameters (Terminals 1, 2, 3):

Uo=8.7V, Io=33mA, Po=72mW

IIC: Co=5εF, Lo=28mH

C(II B): Co=49εF, Lo=84mH